

## 連続測定に関する事項

(単位:°C)

	燃焼炉内温度		冷却缶出口ガス温度		備考
	最大値	最小値	最大値	最小値	
2026/4/1	901	894	78.8	76.7	
2026/4/2	901	899	78.4	76.9	
2026/4/3	902	899	78.2	76.9	
2026/4/4	902	898	78.4	76.5	
2026/4/5	904	897	78.5	76.7	
2026/4/6	902	897	79.0	76.6	
2026/4/7	905	893	77.9	76.1	
2026/4/8	902	884	78.2	76.6	
2026/4/9	903	896	78.6	76.8	
2026/4/10	902	896	78.2	76.9	
2026/4/11	902	897	78.1	76.9	
2026/4/12	902	897	78.1	76.7	
2026/4/13	902	897	78.0	76.7	
2026/4/14	905	893	78.1	76.5	
2026/4/15	901	891	78.0	77.0	
2026/4/16	902	888	77.7	76.7	
2026/4/17	901	896	77.7	76.7	
2026/4/18	902	893	77.8	76.5	
2026/4/19	902	897	77.8	76.7	
2026/4/20	902	897	77.9	76.5	
2026/4/21	903	893	78.5	77.0	
2026/4/22	902	898	78.7	77.2	
2026/4/23	902	898	78.3	77.0	
2026/4/24	903	898	78.4	76.9	
2026/4/25	902	897	78.6	76.8	
2026/4/26	902	897	79.0	77.0	
2026/4/27	902	897	78.8	77.1	
2026/4/28	906	892	78.8	76.7	
2026/4/29	902	896	78.4	76.6	
2026/4/30	902	897	78.5	76.7	