

## 連続測定に関する事項

(単位:°C)

|            | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考         |
|------------|--------|-----|-----------|------|------------|
|            | 最大値    | 最小値 | 最大値       | 最小値  |            |
| 2017/12/1  | —      | —   | —         | —    | 停止中        |
| 2017/12/2  | —      | —   | —         | —    | 停止中        |
| 2017/12/3  | —      | —   | —         | —    | 停止中        |
| 2017/12/4  | —      | —   | —         | —    | 停止中        |
| 2017/12/5  | —      | —   | —         | —    | 停止中        |
| 2017/12/6  | —      | —   | —         | —    | 停止中        |
| 2017/12/7  | —      | —   | —         | —    | 停止中        |
| 2017/12/8  | 902    | 8   | 66.2      | 6.1  | 13:00~昇温開始 |
| 2017/12/9  | 903    | 890 | 84.1      | 61.8 |            |
| 2017/12/10 | 906    | 887 | 83.7      | 81.9 |            |
| 2017/12/11 | 912    | 879 | 83.9      | 80.8 |            |
| 2017/12/12 | 909    | 888 | 81.9      | 77.7 |            |
| 2017/12/13 | 906    | 895 | 79.3      | 77.3 |            |
| 2017/12/14 | 910    | 894 | 82.8      | 78.5 |            |
| 2017/12/15 | 908    | 878 | 82.3      | 78.1 |            |
| 2017/12/16 | 910    | 892 | 81.3      | 78.2 |            |
| 2017/12/17 | 909    | 887 | 81.3      | 79.2 |            |
| 2017/12/18 | 908    | 887 | 81.3      | 77.7 |            |
| 2017/12/19 | 907    | 892 | 80.7      | 77.5 |            |
| 2017/12/20 | 912    | 889 | 80.5      | 77.5 |            |
| 2017/12/21 | 910    | 888 | 80.9      | 78.8 |            |
| 2017/12/22 | 913    | 889 | 81.1      | 78.4 |            |
| 2017/12/23 | 912    | 889 | 81.7      | 79.4 |            |
| 2017/12/24 | 912    | 891 | 81.6      | 78.6 |            |
| 2017/12/25 | 920    | 885 | 81.3      | 78.5 |            |
| 2017/12/26 | 922    | 879 | 81.4      | 73.9 |            |
| 2017/12/27 | 908    | 880 | 76.6      | 74.6 |            |
| 2017/12/28 | 902    | 898 | 76.9      | 75.4 |            |
| 2017/12/29 | 901    | 898 | 77.0      | 75.7 |            |
| 2017/12/30 | 902    | 897 | 77.0      | 75.5 |            |
| 2017/12/31 | 905    | 896 | 77.2      | 75.5 |            |

## 連続測定に関する事項

(単位:°C)

|            | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考         |
|------------|--------|-----|-----------|------|------------|
|            | 最大値    | 最小値 | 最大値       | 最小値  |            |
| 2017/11/1  | 907    | 891 | 86.4      | 78.8 |            |
| 2017/11/2  | 907    | 893 | 86.2      | 84.1 |            |
| 2017/11/3  | 924    | 868 | 85.3      | 84.3 |            |
| 2017/11/4  | 915    | 883 | 86.0      | 84.7 |            |
| 2017/11/5  | 908    | 894 | 85.9      | 84.4 |            |
| 2017/11/6  | 910    | 893 | 85.9      | 84.6 |            |
| 2017/11/7  | 911    | 890 | 85.7      | 84.6 |            |
| 2017/11/8  | 912    | 888 | 85.6      | 79.2 |            |
| 2017/11/9  | 913    | 887 | 85.4      | 82.9 |            |
| 2017/11/10 | 914    | 888 | 86.3      | 66.7 |            |
| 2017/11/11 | 906    | 893 | 86.3      | 84.9 |            |
| 2017/11/12 | 917    | 887 | 86.1      | 84.9 |            |
| 2017/11/13 | 912    | 888 | 86.7      | 77.7 |            |
| 2017/11/14 | 916    | 892 | 85.3      | 71.9 |            |
| 2017/11/15 | 908    | 891 | 82.9      | 80.1 |            |
| 2017/11/16 | 908    | 892 | 83.2      | 80.6 |            |
| 2017/11/17 | 907    | 888 | 84.3      | 81.6 |            |
| 2017/11/18 | 908    | 884 | 84.2      | 82.7 |            |
| 2017/11/19 | 906    | 893 | 84.3      | 82.9 |            |
| 2017/11/20 | 909    | 893 | 84.5      | 83.0 |            |
| 2017/11/21 | 927    | 872 | 85.6      | 81.8 |            |
| 2017/11/22 | 912    | 880 | 85.1      | 82.7 |            |
| 2017/11/23 | 906    | 892 | 84.1      | 82.5 |            |
| 2017/11/24 | 907    | 886 | 85.5      | 82.4 |            |
| 2017/11/25 | 905    | 897 | 84.0      | 82.7 |            |
| 2017/11/26 | 906    | 894 | 82.4      | 80.3 |            |
| 2017/11/27 | 903    | 896 | 82.7      | 80.1 |            |
| 2017/11/28 | 904    | 896 | 83.1      | 80.6 |            |
| 2017/11/29 | —      | —   | —         | —    | 16:30～冷却開始 |
| 2017/11/30 | —      | —   | —         | —    | 10:30～停止中  |
|            |        |     |           |      |            |

## 連続測定に関する事項

(単位:°C)

|            | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考 |
|------------|--------|-----|-----------|------|----|
|            | 最大値    | 最小値 | 最大値       | 最小値  |    |
| 2017/10/1  | 903    | 893 | 85.6      | 84.0 |    |
| 2017/10/2  | 918    | 885 | 85.6      | 84.0 |    |
| 2017/10/3  | 922    | 866 | 86.0      | 84.0 |    |
| 2017/10/4  | 928    | 872 | 85.3      | 83.7 |    |
| 2017/10/5  | 906    | 895 | 86.0      | 85.0 |    |
| 2017/10/6  | 937    | 881 | 86.1      | 85.1 |    |
| 2017/10/7  | 908    | 892 | 85.8      | 84.8 |    |
| 2017/10/8  | 911    | 889 | 85.4      | 84.2 |    |
| 2017/10/9  | 912    | 887 | 85.8      | 84.7 |    |
| 2017/10/10 | 919    | 870 | 86.2      | 85.2 |    |
| 2017/10/11 | 922    | 877 | 86.6      | 85.1 |    |
| 2017/10/12 | 924    | 877 | 86.0      | 80.5 |    |
| 2017/10/13 | 923    | 872 | 86.4      | 85.0 |    |
| 2017/10/14 | 906    | 895 | 86.3      | 85.4 |    |
| 2017/10/15 | 904    | 896 | 86.1      | 84.5 |    |
| 2017/10/16 | 907    | 893 | 85.9      | 84.1 |    |
| 2017/10/17 | 920    | 882 | 85.8      | 84.4 |    |
| 2017/10/18 | 909    | 889 | 86.0      | 84.7 |    |
| 2017/10/19 | 911    | 888 | 86.0      | 84.8 |    |
| 2017/10/20 | 918    | 880 | 86.1      | 84.6 |    |
| 2017/10/21 | 908    | 893 | 86.2      | 84.6 |    |
| 2017/10/22 | 906    | 893 | 86.0      | 84.4 |    |
| 2017/10/23 | 908    | 893 | 85.9      | 84.6 |    |
| 2017/10/24 | 918    | 866 | 86.8      | 84.9 |    |
| 2017/10/25 | 933    | 874 | 86.8      | 84.9 |    |
| 2017/10/26 | 914    | 889 | 86.4      | 84.7 |    |
| 2017/10/27 | 916    | 890 | 87.0      | 85.1 |    |
| 2017/10/28 | 914    | 889 | 87.4      | 85.5 |    |
| 2017/10/29 | 911    | 892 | 86.9      | 84.6 |    |
| 2017/10/30 | 907    | 892 | 86.3      | 84.8 |    |
| 2017/10/31 | 919    | 871 | 86.2      | 75.6 |    |

## 連続測定に関する事項

(単位:°C)

|           | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考 |
|-----------|--------|-----|-----------|------|----|
|           | 最大値    | 最小値 | 最大値       | 最小値  |    |
| 2017/9/1  | 901    | 899 | 85.7      | 84.3 |    |
| 2017/9/2  | 902    | 898 | 85.6      | 84.2 |    |
| 2017/9/3  | 902    | 898 | 85.4      | 83.8 |    |
| 2017/9/4  | 908    | 884 | 85.9      | 84.1 |    |
| 2017/9/5  | 905    | 893 | 85.7      | 83.7 |    |
| 2017/9/6  | 902    | 896 | 85.1      | 83.5 |    |
| 2017/9/7  | 902    | 898 | 85.0      | 84.1 |    |
| 2017/9/8  | 908    | 893 | 85.0      | 83.6 |    |
| 2017/9/9  | 906    | 896 | 85.3      | 83.8 |    |
| 2017/9/10 | 902    | 899 | 86.0      | 84.0 |    |
| 2017/9/11 | 904    | 898 | 86.3      | 84.7 |    |
| 2017/9/12 | 905    | 893 | 86.1      | 84.3 |    |
| 2017/9/13 | 903    | 897 | 85.8      | 84.0 |    |
| 2017/9/14 | 903    | 896 | 85.9      | 83.5 |    |
| 2017/9/15 | 911    | 889 | 85.6      | 84.3 |    |
| 2017/9/16 | 912    | 892 | 85.4      | 83.4 |    |
| 2017/9/17 | 903    | 896 | 85.2      | 83.2 |    |
| 2017/9/18 | 910    | 887 | 85.0      | 83.0 |    |
| 2017/9/19 | 942    | 869 | 85.6      | 76.9 |    |
| 2017/9/20 | 911    | 892 | 85.4      | 84.0 |    |
| 2017/9/21 | 913    | 890 | 85.9      | 84.0 |    |
| 2017/9/22 | 911    | 889 | 85.9      | 84.0 |    |
| 2017/9/23 | 901    | 898 | 85.8      | 85.1 |    |
| 2017/9/24 | 902    | 897 | 85.6      | 84.6 |    |
| 2017/9/25 | 904    | 896 | 85.9      | 84.7 |    |
| 2017/9/26 | 924    | 878 | 85.9      | 84.3 |    |
| 2017/9/27 | 905    | 894 | 86.4      | 84.4 |    |
| 2017/9/28 | 910    | 894 | 86.2      | 84.3 |    |
| 2017/9/29 | 918    | 879 | 86.1      | 83.5 |    |
| 2017/9/30 | 934    | 880 | 86.0      | 84.5 |    |
|           |        |     |           |      |    |

## 連続測定に関する事項

(単位:°C)

|           | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考              |
|-----------|--------|-----|-----------|------|-----------------|
|           | 最大値    | 最小値 | 最大値       | 最小値  |                 |
| 2017/8/1  | 907    | 891 | 86.2      | 84.4 |                 |
| 2017/8/2  | 905    | 897 | 86.3      | 84.8 |                 |
| 2017/8/3  | 903    | 898 | 86.4      | 84.9 |                 |
| 2017/8/4  | 916    | 892 | 86.1      | 84.9 |                 |
| 2017/8/5  | 904    | 897 | 86.9      | 85.6 |                 |
| 2017/8/6  | 910    | 895 | 86.8      | 84.8 |                 |
| 2017/8/7  | 904    | 897 | 85.9      | 84.4 |                 |
| 2017/8/8  | —      | —   | —         | —    | 2:40~冷却開始(部品交換) |
| 2017/8/9  | —      | —   | —         | —    | 停止中             |
| 2017/8/10 | —      | —   | —         | —    | 停止中             |
| 2017/8/11 | —      | —   | —         | —    | 停止中             |
| 2017/8/12 | —      | —   | —         | —    | 停止中             |
| 2017/8/13 | —      | —   | —         | —    | 停止中             |
| 2017/8/14 | —      | —   | —         | —    | 停止中             |
| 2017/8/15 | —      | —   | —         | —    | 停止中             |
| 2017/8/16 | —      | —   | —         | —    | 停止中             |
| 2017/8/17 | —      | —   | —         | —    | 停止中             |
| 2017/8/18 | —      | —   | —         | —    | 停止中             |
| 2017/8/19 | —      | —   | —         | —    | 停止中             |
| 2017/8/20 | —      | —   | —         | —    | 停止中             |
| 2017/8/21 | —      | —   | —         | —    | 停止中             |
| 2017/8/22 | —      | —   | —         | —    | 停止中             |
| 2017/8/23 | —      | —   | —         | —    | 停止中             |
| 2017/8/24 | —      | —   | —         | —    | 停止中             |
| 2017/8/25 | —      | —   | —         | —    | 停止中             |
| 2017/8/26 | —      | —   | —         | —    | 停止中             |
| 2017/8/27 | —      | —   | —         | —    | 停止中             |
| 2017/8/28 | —      | —   | —         | —    | 停止中             |
| 2017/8/29 | —      | —   | —         | —    | 15:00~昇温開始      |
| 2017/8/30 | 905    | 891 | 86.2      | 67.2 | 10:00~燃焼開始      |
| 2017/8/31 | 906    | 891 | 85.8      | 84.5 |                 |

## 連続測定に関する事項

(単位:°C)

|           | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考             |
|-----------|--------|-----|-----------|------|----------------|
|           | 最大値    | 最小値 | 最大値       | 最小値  |                |
| 2017/7/1  | 903    | 898 | 85.3      | 84.3 |                |
| 2017/7/2  | 905    | 894 | 85.6      | 84.5 |                |
| 2017/7/3  | 908    | 891 | 85.3      | 83.9 |                |
| 2017/7/4  | 908    | 892 | 85.4      | 84.1 |                |
| 2017/7/5  | 901    | 899 | 84.7      | 83.8 |                |
| 2017/7/6  | 911    | 889 | 85.1      | 83.7 |                |
| 2017/7/7  | 911    | 890 | 85.1      | 84.4 |                |
| 2017/7/8  | 905    | 898 | 85.4      | 84.2 |                |
| 2017/7/9  | 908    | 892 | 85.5      | 83.3 |                |
| 2017/7/10 | 911    | 891 | 85.7      | 84.3 |                |
| 2017/7/11 | —      | —   | —         | —    | 9:00～データ送受信不調  |
| 2017/7/12 | 915    | 885 | 85.7      | 84.6 | 15:00～データ送受信復旧 |
| 2017/7/13 | 903    | 897 | 85.4      | 84.5 |                |
| 2017/7/14 | 940    | 866 | 85.7      | 84.5 |                |
| 2017/7/15 | 902    | 897 | 86.0      | 84.9 |                |
| 2017/7/16 | 903    | 897 | 86.0      | 85.0 |                |
| 2017/7/17 | 903    | 895 | 85.6      | 84.4 |                |
| 2017/7/18 | 953    | 863 | 85.9      | 67.7 |                |
| 2017/7/19 | 908    | 888 | 86.1      | 83.7 |                |
| 2017/7/20 | 904    | 897 | 86.1      | 84.0 |                |
| 2017/7/21 | 927    | 871 | 86.7      | 84.5 |                |
| 2017/7/22 | 903    | 898 | 86.1      | 84.4 |                |
| 2017/7/23 | 903    | 898 | 86.1      | 84.6 |                |
| 2017/7/24 | 907    | 880 | 86.5      | 84.6 |                |
| 2017/7/25 | 927    | 865 | 86.4      | 81.9 |                |
| 2017/7/26 | 905    | 897 | 85.8      | 84.5 |                |
| 2017/7/27 | 906    | 895 | 85.9      | 84.6 |                |
| 2017/7/28 | 910    | 893 | 85.8      | 84.6 |                |
| 2017/7/29 | 906    | 896 | 85.7      | 84.7 |                |
| 2017/7/30 | 902    | 898 | 86.1      | 84.7 |                |
| 2017/7/31 | 905    | 897 | 86.2      | 84.6 |                |

## 連続測定に関する事項

(単位:°C)

|           | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考         |
|-----------|--------|-----|-----------|------|------------|
|           | 最大値    | 最小値 | 最大値       | 最小値  |            |
| 2017/6/1  | 910    | 23  | 68.9      | 19.1 | 13:00～昇温開始 |
| 2017/6/2  | 903    | 896 | 80.6      | 64.0 |            |
| 2017/6/3  | 902    | 898 | 80.0      | 79.4 |            |
| 2017/6/4  | 903    | 898 | 80.1      | 79.5 |            |
| 2017/6/5  | 916    | 876 | 84.4      | 78.6 |            |
| 2017/6/6  | 904    | 896 | 84.3      | 83.6 |            |
| 2017/6/7  | 903    | 895 | 84.7      | 83.0 |            |
| 2017/6/8  | 903    | 895 | 84.1      | 83.3 |            |
| 2017/6/9  | 934    | 878 | 85.0      | 81.7 |            |
| 2017/6/10 | 902    | 898 | 85.2      | 84.4 |            |
| 2017/6/11 | 905    | 896 | 86.2      | 84.7 |            |
| 2017/6/12 | 907    | 892 | 86.2      | 84.8 |            |
| 2017/6/13 | 919    | 880 | 86.3      | 79.6 |            |
| 2017/6/14 | 908    | 742 | 86.1      | 50.8 | 17:00～冷却開始 |
| 2017/6/15 | —      | —   | —         | —    | 3:00～停止    |
| 2017/6/16 | —      | —   | —         | —    | 停止中        |
| 2017/6/17 | —      | —   | —         | —    | 停止中        |
| 2017/6/18 | —      | —   | —         | —    | 停止中        |
| 2017/6/19 | 903    | 35  | 64.8      | 19.6 | 13:00～昇温開始 |
| 2017/6/20 | 928    | 889 | 84.8      | 57.9 |            |
| 2017/6/21 | 905    | 891 | 84.8      | 82.6 |            |
| 2017/6/22 | 902    | 897 | 85.3      | 82.8 |            |
| 2017/6/23 | 907    | 890 | 84.5      | 83.1 |            |
| 2017/6/24 | 905    | 897 | 85.0      | 83.3 |            |
| 2017/6/25 | 903    | 897 | 84.5      | 82.6 |            |
| 2017/6/26 | 917    | 877 | 84.6      | 82.8 |            |
| 2017/6/27 | 909    | 897 | 85.0      | 83.3 |            |
| 2017/6/28 | 903    | 898 | 85.5      | 83.6 |            |
| 2017/6/29 | 926    | 868 | 85.4      | 83.6 |            |
| 2017/6/30 | 911    | 888 | 85.8      | 83.9 |            |
|           |        |     |           |      |            |

## 連続測定に関する事項

(単位:°C)

|           | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考           |
|-----------|--------|-----|-----------|------|--------------|
|           | 最大値    | 最小値 | 最大値       | 最小値  |              |
| 2017/5/1  | 909    | 894 | 87.1      | 84.2 |              |
| 2017/5/2  | 910    | 891 | 86.5      | 80.1 |              |
| 2017/5/3  | 904    | 896 | 82.8      | 80.1 |              |
| 2017/5/4  | 907    | 894 | 82.4      | 79.8 |              |
| 2017/5/5  | 907    | 896 | 83.2      | 80.0 |              |
| 2017/5/6  | 906    | 896 | 82.9      | 79.8 |              |
| 2017/5/7  | 907    | 894 | 80.8      | 79.7 |              |
| 2017/5/8  | 914    | 889 | 87.3      | 80.3 |              |
| 2017/5/9  | 911    | 893 | 87.7      | 83.7 |              |
| 2017/5/10 | 908    | 884 | 85.3      | 83.3 |              |
| 2017/5/11 | 913    | 880 | 87.6      | 67.4 |              |
| 2017/5/12 | 912    | 878 | 87.1      | 79.0 |              |
| 2017/5/13 | 901    | 898 | 81.0      | 79.2 |              |
| 2017/5/14 | 901    | 899 | 81.0      | 79.0 |              |
| 2017/5/15 | 901    | 898 | 80.8      | 79.0 |              |
| 2017/5/16 | 901    | 899 | 81.0      | 79.2 |              |
| 2017/5/17 | 918    | 894 | 81.2      | 78.9 |              |
| 2017/5/18 | 901    | 899 | 79.5      | 78.5 |              |
| 2017/5/19 | 901    | 899 | 81.6      | 78.4 |              |
| 2017/5/20 | 901    | 899 | 79.4      | 78.4 |              |
| 2017/5/21 | 961    | 732 | 78.9      | 50.5 | 15:00～冷却開始   |
| 2017/5/22 | —      | —   | —         | —    | 9:00～停止      |
| 2017/5/23 | —      | —   | —         | —    | 停止中(計画停電)    |
| 2017/5/24 | —      | —   | —         | —    | 停止中(停電～電源復帰) |
| 2017/5/25 | —      | —   | —         | —    | 停止中          |
| 2017/5/26 | —      | —   | —         | —    | 停止中          |
| 2017/5/27 | —      | —   | —         | —    | 停止中          |
| 2017/5/28 | —      | —   | —         | —    | 停止中          |
| 2017/5/29 | —      | —   | —         | —    | 停止中          |
| 2017/5/30 | —      | —   | —         | —    | 停止中          |
| 2017/5/31 | —      | —   | —         | —    | 停止中          |



## 連続測定に関する事項

(単位:°C)

|           | 燃焼炉内温度 |     | 冷却缶出口ガス温度 |      | 備考 |
|-----------|--------|-----|-----------|------|----|
|           | 最大値    | 最小値 | 最大値       | 最小値  |    |
| 2017/4/1  | 905    | 896 | 84.9      | 82.8 |    |
| 2017/4/2  | 904    | 894 | 84.4      | 82.6 |    |
| 2017/4/3  | 903    | 895 | 84.5      | 83.0 |    |
| 2017/4/4  | 903    | 893 | 84.9      | 82.8 |    |
| 2017/4/5  | 903    | 896 | 85.1      | 83.5 |    |
| 2017/4/6  | 907    | 896 | 85.4      | 83.8 |    |
| 2017/4/7  | 909    | 896 | 86.0      | 83.6 |    |
| 2017/4/8  | 906    | 891 | 85.5      | 83.7 |    |
| 2017/4/9  | 904    | 894 | 85.8      | 84.0 |    |
| 2017/4/10 | 905    | 894 | 85.9      | 84.3 |    |
| 2017/4/11 | 905    | 897 | 85.8      | 84.1 |    |
| 2017/4/12 | 903    | 897 | 85.2      | 83.3 |    |
| 2017/4/13 | 902    | 897 | 85.3      | 83.0 |    |
| 2017/4/14 | 909    | 894 | 85.7      | 84.2 |    |
| 2017/4/15 | 903    | 895 | 85.3      | 84.1 |    |
| 2017/4/16 | 905    | 895 | 85.9      | 84.2 |    |
| 2017/4/17 | 903    | 897 | 87.2      | 84.4 |    |
| 2017/4/18 | 909    | 891 | 86.7      | 83.8 |    |
| 2017/4/19 | 902    | 898 | 85.5      | 83.7 |    |
| 2017/4/20 | 903    | 897 | 85.2      | 83.4 |    |
| 2017/4/21 | 906    | 895 | 85.7      | 83.8 |    |
| 2017/4/22 | 903    | 898 | 85.7      | 83.9 |    |
| 2017/4/23 | 903    | 897 | 86.1      | 84.1 |    |
| 2017/4/24 | 904    | 894 | 86.4      | 84.5 |    |
| 2017/4/25 | 906    | 893 | 86.9      | 85.0 |    |
| 2017/4/26 | 907    | 895 | 86.5      | 84.7 |    |
| 2017/4/27 | 909    | 892 | 86.1      | 83.9 |    |
| 2017/4/28 | 908    | 886 | 86.9      | 84.9 |    |
| 2017/4/29 | 909    | 890 | 86.2      | 83.2 |    |
| 2017/4/30 | 958    | 877 | 86.2      | 81.8 |    |
|           |        |     |           |      |    |